



RADON Reduction System

Active Soil Depressurization System

DO NOT TURN OFF FAN

An active soil depressurization system has been designed, installed, and is operating in this building. The fan must remain on at all times.

The radon system pressure gauge should be checked periodically. Contact a C-NRPP Mitigation Professional if the pressure gauge readings are outside the normal operating range.

TEST YOUR HOME FOR RADON

Re-test your home for radon every 5 years, or after making changes to your heating, cooling, or ventilation systems, or after renovations.

For more information, visit www.c-nrpp.ca/radonreduction

Installer's Name: _____

Installers Contact: _____

C-NRPP #: _____

Date of Installation: _____

Suction Pressure: _____ in pascal or "WC"